

**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 11:22 AM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 115 Const Calendar Day: 302 Date: 07-Jul-2010 Wednesday

Inspector Name: Wilcox, Jason Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 06:30 am 05:00 pm Break: 00:30 Over Time: 02:00

Federal ID:

Location:

Reviewer: Jefferson, Paul Approved Date: 11-Nov-13 Status: Approved

**04-0120F4
04-SF-80-13.2/13.9
Self-Anchored
Suspension Bridge****Weather****Temperature** 7 AM 40 - 50 12 PM 50 - 60 4PM 50 - 60**Precipitation** **Condition** ClearWorking Day ☒ If no, explain:**Diary:**

Dispute

General Comments

See Thanh Le's diary for details on the W-Line and David Bradd's for the E-Line

- Spoke with Thanh about the U-rib gaps of 5W/6W.
 - Field visit to observe the 5W/6W connection.
 - Some of the offsets at the 5W/6W U-ribs are up to 7mm. I reviewed Submittal 1217 and RFI 1766 to go over the requirements. I then brought them out to review them with Thanh.
 - Review Submittal 1637
 - Review Plans and Specs
 - Diary work
- Accrued 2 hours of overtime covering the Contractor's hours.

